GENERAL NOTES

A. SEE SHEET TA-001 FOR SYMBOL SCHEDULE AND GENERAL NOTES.

		SYSTEM OUTPUTS															
		ANNUNCIATION							NOTIFICATION		FIRE SAFETY						
	SYSTEM INPUTS	PANEL INDICATES TROUBLE	PANEL INDICATES AC POWER TROUBLE	PANEL INDICATES BATTERY TROUBLE	PANEL INDICATES ALARM	PANEL INDICATES DESCRIPTION OF EVENT	PANEL INDICATES SUPERVISORY	PANEL INDICATES DUCT SMOKE DETECTOR SUPERVISORY	ACTIVATE SPEAKER/STROBES THROUGHOUT THE INDIVIDUAL AREA (OFFICES/STORAGE, WET PROCESS, DRY PROCESS)	ACTIVATES EXTERIOR SPEAKER STROBE	ALARM, TROUBLE, OR SUPERVISORY IS TRANSMITTED TO THE SECURITY COMMAND CENTER	AIR HANDLING UNIT SHUTDOWN	RELEASE DOOR HOLD OPEN DEVICES	ACTIVATE ACCESS CONTROL RELAYS FOR EGRESS DOORS AND GATES
STATUS	LOW BATTERY	X		X		X					X			
	AC POWER LOSS	X	X			X					X			
	SINGLE OPEN ON SLC/NAC CIRCUIT	X				X					X			
	SHORT ON SLC/NAC CIRCUIT	X				X					X			
	GROUND FAULT	X				X					X			
INITIATION	MANUAL PULL STATION				X	X			X		X		X	X
	SMOKE DETECTORS				X	X			X		X		X	X
	MONITOR MODULES - FLOW SWITCH				X	X			X	X	X		X	X
	DUCT SMOKE DETECTORS					X	X				X	X		
	DUCT SMOKE REMOTE TEST STATION							X						
	HEAT DETECTORS				X	X			X		X		X	X
EXTERNAL SYSTEM INPUTS	FIRE SUPPRESSION PANEL - ALARM				X	X			X		X		X	X
	FIRE SUPPRESSION PANEL - TROUBLE	X				X					X			
	FIRE SUPPRESSION PANEL - SUPERVISORY					X					X			
	REMOTE MICROPHONE MESSAGE													
	GAS DETECTION SYSTEM - ALARM				X	X			X		X		X	X
	GAS DETECTION SYSTEM - TROUBLE	X				X					X			
	GAS DETECTION SYSTEM - SUPERVISORY					X					X			

1 FIRE ALARM SEQUENCE OF OPERATION

SCALE: NOT TO SCALE

TB_REV 1.0

ssoe®

CONSULTANTS:

Issued For CONSTRUCTION
06/06/2022
www.ssoe.com

SEAL ON THIS DOCUMENT AUTHORIZED BY:

APPLY STAMP IN BLUEBEAM

PROJECT INFORMATION:

BROWNFIELD MODIFICATIONS

CLIENT INFORMATION:

ASCEND ELEMENTS

ASCEND ELEMENTS
9172 INDUSTRIAL DR NE
COVINGTON, GA
30014

CLIENT PROJECT NO: XXX-XXXXX-XX

NO.	DATE	REVISION OR ISSUE
A	06/06/22	ISSUED FOR IFC

SSOE, Inc.
1001 Madison Avenue
Toledo, OH 43604
T. (419) 255-3830

PROJECT NO: 021-01975-00
PROJECT MANAGER: R. FOX
DESIGNED: J. DELANEY
CHECKED: M. SMITH

DRAWING TITLE:
FIRE ALARM SEQUENCE OF OPERATION

DRAWING NO:
TF-802

BIM 360://Battery Resources Brownfield Modifications/021019750O_T20_SSOE.rvt
DATE: 6/6/2022 5:19:01 PM