GENERAL NOTES

LIGHTING FIXTURE SCHEDULE

TYPE	Model	DESCRIPTION	MANUFACTURER	VOLTAGE	APPARENT LOAD
L1	LXEM4-50VW-RFP-EDU	LED ENCLOSURE AND GASKETED 4' STRIP, FIBERGLASS HOUSING, 3433 LUMENS, 5000K CCT, RIBBED FROSTED POLYCARBONATE LENS.	HUBBELL LIGHTING OR EQUAL BY ACUITY BRANDS	277 V	35 VA
L1E	LXEM4-50VW-RFP-EDU-ELL14	SAME AS TYPE L1, EXCEPT WITH INTEGRAL BATTERY BACKUP	HUBBELL LIGHTING OR EQUAL BY ACUITY BRANDS	277 V	35 VA
L2	SRP24-50MLHE-G-EDU	LED 2' x 4' EDGE LIT FLAT PANEL TROFFER, 5152 LUMENS, 5000K CCT.	HUBBELL LIGHTING OR EQUAL BY ACUITY BRANDS	277 V	35 VA
L2E	SRP24-50MLHE-G-EDU-ELL14	SAME AS TYPE L2, EXCEPT WITH INTEGRAL BATTERY BACKUP	HUBBELL LIGHTING OR EQUAL BY ACUITY BRANDS	277 V	35 VA
L3E	ESL4-50MWHE-FPW-EDU-ELL14	4' LED STAIR LIGHT, SURFACE MOUNT, STEEL HOUSING, POLYCARBONATE LENS, 3600 LUMENS, 5000K CCT, INTEGRAL BATTERY BACKUP	HUBBELL LIGHTING OR EQUAL BY ACUITY BRANDS	277 V	55 VA
L4	LTR-6RD-H-SL06L-DM1 LTR-6RD-T-SL50K8MDS	6" RECESSED DOWNLIGHT, 600 LUMENS, 90 CRI, 5000K CCT, MEDIUM DISTRIBUTION, SPECULAR CLEAR FINISH, WET LOCATION LISTED	HUBBELL LIGHTING OR EQUAL BY ACUITY BRANDS	277 V	23 VA
L4E	LTR-6RD-H-ML20L-DM1-EMR LTR-6RD-T-ML50K8MDSTR-6RD-T-SL50K8MDS	SAME AS TYPE L4, EXCEPT WITH INTEGRAL BATTERY BACKUP	HUBBELL LIGHTING OR EQUAL BY ACUITY BRANDS	277 V	23 VA
L5	SRP24-50MW-G-EDU	LED 2' x 4' EDGE LIT FLAT PANEL TROFFER, 4091 LUMENS, 5000K CCT.	HUBBELL LIGHTING OR EQUAL BY ACUITY BRANDS	277 V	35 VA
L5E	SRP24-50MW-G-EDU-ELL14	SAME AS TYPE L5, EXCEPT WITH INTEGRAL BATTERY BACKUP	HUBBELL LIGHTING OR EQUAL BY ACUITY BRANDS	277 V	35 VA
L6	SRP24-50XW-G-EDU	LED 2' x 4' EDGE LIT FLAT PANEL TROFFER, 2886 LUMEN, 5000K CCT.	HUBBELL LIGHTING OR EQUAL BY ACUITY BRANDS	277 V	35 VA
L6E	SRP24-50XW-G-EDU-ELL14	SAME AS TYPE L6, EXCEPT WITH INTEGRAL BATTERY BACKUP	HUBBELL LIGHTING OR EQUAL BY ACUITY BRANDS	277 V	35 VA
L7	2L-W-AS-4-ASM-CX-50K-D075	4FT WALL MOUNTED LIGHT, AYSEMMETRIC DIRECT LENS, 3000 LUMENS, 5000K CCT.	HUBBELL LIGHTING OR EQUAL BY ACUITY BRANDS	277 V	28 VA
L8E	LSQ1-25-5K7-UNV-E	2' x 2' CANOPY LIGHT, 3000 LUMENS, 5000K CCT, WITH INTEGRAL BATTERY BACKUP.	HUBBELL LIGHTING OR EQUAL BY ACUITY BRANDS	277 V	24 VA
P4	AL22-100L-200-4S-4-UNV	SITE LIGHT FIXTURE ON 20' ROUND TAPERED ALUMINUM POLE, 25,004 LUMENS, 4000K CCT, 70 CRI, DISTRIBUTION TYPE IV	HUBBELL LIGHTING OR EQUAL BY ACUITY BRANDS	277 V	168 VA
W1E	LNC2-9L-5K-070-4-U-DBS-PCU-EH	LED BUILDING MOUNTED EGRESS LIGHT, 2097 LUMENS, 5000K CCT, INTEGRAL PHOTOCELL AND BATTERY BACKUP	HUBBELL LIGHTING OR EQUAL BY ACUITY BRANDS	277 V	22 VA
X1	PETPE-UR-30	LED EXIT SIGN WITH WHITE THERMOPLASTIC HOUSING, RED LETTERS, LONG-LIFE NI-CAD BATTERY, ARROWS AS INDICATED ON DRAWINGS	HUBBELL LIGHTING OR EQUAL BY ACUITY BRANDS	277 V	3 VA

C

TB_REV 1.0

SSOE®

CONSULTANTS:

Issued For
BULLETIN
06/06/2022
www.ssoe.com

SEAL ON THIS DOCUMENT AUTHORIZED BY:

GEORGIA REGISTERED No. PE035731 PROFESSIONAL 6/6/22 ENGINEER FRANK M. ROWE

PROJECT INFORMATION:

BROWNFIELD MODIFICATIONS

CLIENT INFORMATION:

ASCEND ELEMENTS
ASCEND ELEMENTS
9172 INDUSTRIAL DR NE
COVINGTON, GA
30014

CLIENT PROJECT NO: XXX-XXXXX-XX

NO.	DATE	SUBJECT
C	06/06/22	BULLETIN 1 - PKG 11E01
B	05/03/22	FOR CONSTRUCTION - PKG 11E01
A	04/28/22	FOR PERMIT - PKG 11E01

REVISION OR ISSUE

SSOE, Inc.
1001 Madison Avenue
Toledo, OH 43604
T. (419) 255-3830

PROJECT NO: 021-01975-00
PROJECT MANAGER: R. FOX
DESIGNED: D. WOODS
CHECKED: F. ROWE

DRAWING TITLE:
LIGHTING FIXTURE SCHEDULE

DRAWING NO:
EL-600

BIM 360://Battery Resources Brownfield Modifications/021019750O_E20_SSOE.rvt
DATE: 6/6/2022 4:45:25 PM